

# ***Annual Drinking Water Quality Report 2023***

Latham Water District • 347 Old Niskayuna Road • Latham, NY 12110  
(Public Water Supply ID # NY0100198)  
American Water Works Association member since 1952

## **TOWN BOARD MEMBERS**

***Peter G. Crummey, Town Supervisor***

*Rick Field, Deputy Supervisor*

*Alvin Gamble*

*Jeff Madden*

*Kristen Blais*

*Melissa Jeffers*

*Mark McCumber*

## **INTRODUCTION**

To comply with State and Federal regulations, Latham Water District is annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your awareness of drinking water and understanding of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not exceed any maximum contaminant level or violate any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains and how it compares to State standards.

If you have any questions about this report or your drinking water, please contact the Superintendent of the Division of Latham Water, Daniel Seaver, P.E. at 518-783-2750. This report can also be found on our website – [www.colonie.org/departments/lathamwater](http://www.colonie.org/departments/lathamwater). We want you to be informed about your drinking water and the public is invited to participate in the decisions that affect the Division of Latham Water. These decisions are made by the Town Board at their regularly scheduled meetings or at special public hearings. Town Board members Rick Field and Alvin Gamble are Latham Water's liaisons to the Board. Public notice of all meetings is printed in the Colonie Spotlight and can



also be found on the Town of Colonie website at [www.colonie.org/boards/townboard](http://www.colonie.org/boards/townboard). Generally, Town Board meetings are held on the 2<sup>nd</sup> and 4<sup>th</sup> Thursdays of each month.

### ***WHERE DOES OUR WATER COME FROM?***

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that



may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amounts of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Latham's raw water sources are a blend of the Mohawk River and five (5) wells located on Onderdonk Avenue. The Stony Creek Reservoir continues to be utilized as an emergency raw water source. The Stony Creek Reservoir is located in the Town of Clifton Park, NY and was not used in 2023 as a raw water source. Although there has been no

recorded contamination of the Reservoir, potential sources can include highway runoff (de-icing chemicals and sand), residential lawn care runoff, agricultural runoff and accidental spills.

The wells are located on the treatment plant property and are used year-round. One of the wells is used at all times in an effort to "cycle" recharge to the groundwater table. Although there has been no recorded contamination of the wells, potential sources can include agricultural runoff, industrial discharges and accidental spills.

The quality of our sources before treatment is good and the treatment plant finishes the job by removing any solids, metals (primarily iron and manganese), color-producing compounds or other organic and inorganic compounds. At the treatment plant, we continuously monitor the clarity and disinfectant level to ensure the bacteriological safety of the water. Chemical treatment consists of oxidation, coagulation, chlorination and pH adjustment. Physical treatment consists of flocculation, settling and filtration.

## ***SOURCE WATER ASSESSMENTS***

The NYS DOH has completed a Source Water Assessment for the Mohawk River upstream of the Latham Water intake and the Stony Creek Reservoir. The assessments are summarized below. The assessments have identified potential contamination. It does not mean that the water delivered to your home is or will become unsafe to drink.

The assessment of the Mohawk River found that the amount of pasture in its watershed results in a potential for protozoa contamination. While there are many facilities present along the Mohawk that are permitted to discharge, they do not represent an important threat to source water quality.

The assessment of the Stony Creek Reservoir found that the amount of agricultural lands and the golf course in its watershed results in a potential for protozoa, phosphorus and pesticide contamination.

Latham Water District's Mohawk View Water Treatment Plant performs multi-level treatment to insure you receive safe drinking water. Additionally, as this annual report shows, your water is routinely monitored to a great number of potential contaminants.

## ***FACTS AND FIGURES***

The total water produced for 2023 was over 3.78 billion gallons. Our water system serves approximately 85,590 people through 25,536 service connections. Virtually all of this water is sold through metered connections. A portion of the water produced by the treatment plant, however, is not billed to our customers. Unbilled water is used for treatment plant operations, water main testing, fire hydrant flushing, firefighting, water main breaks, etc. We estimate this "unbilled" amount of water to be 18.8 % of water produced. The daily average of water treated and pumped into the distribution system is 10,480,461 gallons per day. In 2023, customers were charged \$4.50 per 1,000 gallons of water for an average annual charge, per residential user, of \$331.78.

## ***ARE THERE CONTAMINANTS IN OUR DRINKING WATER?***

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiologicals and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, is more than one-year-old.



It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects

can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Albany County Health Department at 518-447-4620. Latham Water District routinely tests your drinking water for numerous contaminants. Bacteriological and Total Coliform testing is performed a minimum of 90 times per month and routine physical and chemical testing is performed every day, sometimes as often as every 4 hours.

Turbidity and chlorine residual monitoring are performed continuously, using automated on-line measuring devices as well as manual sample verification. Other contaminants tested for include: inorganic compounds, synthetic and naturally occurring organic compounds, nitrate, lead and copper, volatile organic compounds, total trihalomethane and haloacetic acids. None of the compounds we analyzed for were detected in your drinking water above the maximum contaminant level as defined by the State drinking water standards.

**Table of Detected Contaminants**

Contaminant	Violation Yes/No	Date or Frequency of Sample	Level Detected Average or Max (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, MRDL, TT, or AL)	Likely Source of Contamination
<b>Microbiological Contaminants</b>							
Total Coliform <sup>1</sup>	No	Weekdays	1 positive sample	n/a	n/a	TT=2 or more positive samples	Naturally occurring
Turbidity <sup>2</sup>	No	Continuous	0.22 100% <0.3	NTU	n/a	TT=≤1.0 TT=95% of samples ≤0.3	Soil runoff
Distribution Turbidity <sup>2</sup>	No	Weekdays	0.114 (0.022-0.932)	NTU	n/a	MCL=5	Soil runoff
<b>Inorganic Contaminants</b>							
Copper <sup>3</sup>	No	7/2023 to 12/2023	0.16 (0.06-0.28)	mg/L	1.3	AL=1.3	Corrosion of pipes
Lead <sup>4</sup>	No	7/2023 to 12/2023	0.002 (<0.001-0.016)	mg/L	0	AL=0.015	Corrosion of pipes
Barium	No	10/4/2023	0.032	mg/L	n/a	MCL=2.0	Erosion of natural deposits
Nitrate, Nitrogen (as N)	No	10/4/2023	0.55	mg/L	10	MCL=10	Runoff from fertilizer
Sodium <sup>5</sup>	No	10/4/2023	49.2	mg/L	0	20 270	Naturally occurring
Sulfate	No	10/4/2023	66	mg/L	N/A	MCL-250	Naturally occurring
Color	No	Weekdays	1 (1-3)	CU	n/a	MCL=15	Naturally occurring
Chloride	No	Weekly	39.2 (24.2-85.2)	mg/L	n/a	MCL=250	Naturally occurring or road salt

<b>Table of Detected Contaminants</b>							
Contaminant	Violation Yes/No	Date or Frequency of Sample	Level Detected Average or Max (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, MRDL, TT, or AL)	Likely Source of Contamination
Hardness, as CaCO <sub>3</sub>	No	Weekly	123.9 (97.4-155.0)	mg/L	n/a	n/a	Naturally occurring
<b>Inorganic Contaminants</b>							
Manganese	No	1/16/2019 4/17/2019	1.80 (1.12-2.47)	µg/L	n/a	MCL=300	Naturally occurring
<b>Synthetic Organic Contaminants</b>							
Total Glycol	No	Monthly October to April	0.09 (ND-0.50)	mg/L	n/a	MCL=1	Used in antifreeze and deicing solvents
<b>Disinfection Byproducts</b>							
Total Trihalomethanes <sup>6</sup>	No	Quarterly	55.5 (20.5-80.3)	µg/L	n/a	MCL=80	Byproducts of drinking water chlorination
Haloacetic Acids <sup>6</sup>	No	Quarterly	30.5 (17.0-38.2)	µg/L	n/a	MCL=60	Byproducts of drinking water chlorination
Brominated Haloacetic Acids	No	1/16/2019 4/17/2019	3.44 (<0.300-19.6)	µg/L	n/a	n/a	Byproducts of drinking water chlorination
Total Organic Carbon <sup>7</sup>	No	Monthly	1.8 (1.1-2.2)	Compliance Ratio	n/a	TT=Compliance Ratio ≥1	Naturally occurring
Entry Point Chlorine	No	Continuous	2.11 (1.24-2.80)	mg/L	4	MRDL=4	Added disinfectant
Distribution Chlorine	No	Weekdays	1.23 (0.02-2.05)	mg/L	4	MRDL=4	Added disinfectant

<b>Table of Detected Contaminants</b>							
Contaminant	Violation Yes/No	Date or Frequency of Sample	Level Detected Average or Max (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, MRDL, TT, or AL)	Likely Source of Contamination
Entry Point Chlorine Dioxide	No	Daily	0.02 (<0.01-0.15)	mg/L	0.8	MRDL=0.8	Byproduct of drinking water chlorination
Entry Point Chlorite	No	Daily	0.35 (0.08-0.64)	mg/L	1.0	MRDL=1.0	Byproduct of drinking water chlorination
<b>Disinfection Byproducts</b>							
Distribution Chlorite <sup>8</sup>	No	Monthly	338 (10-740)	µg/L	800	MCL=1000	Byproduct of drinking water chlorination
Distribution Chlorate <sup>8</sup>	No	Monthly	232 (10-350)	µg/L	n/a	n/a	Byproduct of drinking water chlorination
<b>Radioactive Contaminants</b>							
Combined Radium 226 and Radium 228	No	1/4/2023	0.605	pCi/L	0	MCL=5	Erosion of natural deposits
Total Uranium	No	1/4/2023	0.012	µg/L	0	MCL=30	Erosion of natural deposits
Gross Beta Particles <sup>9</sup>	No	1/4/2023	0.713	pCi/L	0	MCL=50	Decay of natural deposits and man-made emissions

**Notes:**

<sup>1</sup> A Level 1 assessment is triggered if 2 or more routine/repeat samples are total coliform positive in the same month.

<sup>2</sup> Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Our highest single turbidity measurement for the year occurred on 10/15/2023 (0.22 NTU), which was due to an instrumentation issue. A treatment technique violation occurs if more than five percent of the composite filter effluent measurements taken each month exceed 0.3 NTU. The turbidity level of representative samples of the filtered water must at no time exceed 1 NTU. We monitor distribution turbidity because high turbidity can hinder the effectiveness of disinfectants. Our highest single distribution turbidity measurement for the year occurred on 5/19/2023 (0.932 NTU), with a monthly average of 0.162 NTU. A violation occurs when the monthly average of the results of all distribution samples collected in any calendar month exceeds 5 NTU. All levels recorded were within the acceptable range allowed and did not constitute a treatment technique violation.

<sup>3</sup> The level presented represents the 90th percentile of the 60 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected in the water system. In this case, 60 samples were collected in the water system and the 90th percentile value was the seventh highest sample (0.16 mg/L). The action level for copper was not exceeded at any of the sites tested.

<sup>4</sup> The level presented represents the 90th percentile of the 60 sites tested. The action level for lead was not exceeded at any of the sites tested.

<sup>5</sup> Water containing more than 20 mg/L of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/L of sodium should not be used for drinking by people on moderately restricted sodium diets.

<sup>6</sup> The level presented represents the highest locational running annual average calculated from data collected. Total trihalomethanes and haloacetic acids are formed by the reaction of chlorine with naturally occurring organic material.

<sup>7</sup> The Interim Enhanced Surface Water Treatment Rule requires monitoring of raw and finished water for Total Organic Carbon (TOC). Depending on raw water alkalinity, water treatment should remove between 15-50% of the raw water TOC to reduce the amount of disinfection byproducts produced. The removal, or compliance ratio, should be greater than or equal to 1 for each quarter. All levels recorded were within the acceptable range allowed and did not constitute a treatment technique violation.

<sup>8</sup> Chlorite and chlorate are formed by the reaction of chlorine dioxide with naturally occurring organic material.

<sup>9</sup> The state considers 50 pCi/L to be a level of concern for beta particles.

**Definitions:**

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements which a water system must follow.

Color Unit (CU): A measure of the color of water. 1 CU equals the yellow color produced by 1 mg of platinum cobalt dissolved in 1 liter of water.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as possible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Micrograms per liter ( $\mu\text{g/L}$ ): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Milligrams per liter (mg/L): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Nephelometric Turbidity Unit (NTU): A measure of particles in water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND): Laboratory Analysis indicates that the constituent is not present.

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

**The following contaminants were tested for, but not found in the Latham Water District's finished water:**

Antimony, Arsenic, Beryllium, Cadmium, Chromium, Cyanide, Mercury, Nickel, Selenium, Thallium, Fluoride, Benzene, Bromobenzene, Bromochloromethane, Bromomethane, N-Butylbenzene, Sec-Butylbenzene, Tert-Butylbenzene, Carbon Tetrachloride, Chlorobenzene, Chloroethane, Chloromethane, 2-Chlorotoluene, 4-Chlorotoluene, Dibromomethane, 1,2-Dichlorobenzene, 1,3-Dichlorobenzene, 1,4-Dichlorobenzene, Dichlorodifluoromethane, 1,1-Dichloroethane, 1,2-Dichloroethane, 1,1-Dichloroethene, cis-1,2-Dichloroethene, trans-1,2-Dichloroethene, 1,2-Dichloropropane, 1,3-Dichloropropane, 2,2-Dichloropropane, 1,1-Dichloropropene, cis-1,3-Dichloropropene, Trans-1,3-Dichloropropene, ethylbenzene, hexachlorobutadiene, Isopropylbenzene, p-Isopropyltoluene, Methylene Chloride, n-Propylbenzene, Styrene, 1,1,1,2-Tetrachloroethane, 1,1,2,2-Tetrachloroethane, Tetrachloroethene, Toluene, 1,2,3-Trichlorobenzene, 1,2,4-Trichlorobenzene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethene, Trichlorofluoromethane, 1,2,3-Trichloropropane, 1,2,4-Trimethylbenzene, 1,3,5-Trimethylbenzene, m-Xylene, o-Xylene, p-Xylene, Vinyl chloride, Methyl-tertiary-butyl-ether, Naphthalene, Gross Alpha Particles, 11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF<sub>3</sub>OUdS), 1H,1H, 2H, 2H-perfluorodecane sulfonic acid (8:2FTS), 1H,1H, 2H, 2H-perfluorohexane sulfonic acid (4:2FTS), 1H,1H, 2H, 2H-perfluorooctane sulfonic acid (6:2FTS), 4,8-dioxa-3H-perfluorononanoic acid (ADONA), 9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF<sub>3</sub>ONS), hexafluoropropylene oxide dimer acid (HFPO-DA)(GenX), nonafluoro-3,6-dioxaheptanoic acid (NFDHA), perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA), perfluoro-3-methoxypropanoic acid (PFMPA), perfluoro-4-methoxybutanoic acid (PFMBA), perfluorobutanesulfonic acid (PFBS), perfluorobutanoic acid (PFBA), perfluorodecanoic acid (PFDA), perfluorododecanoic acid (PFDoA), perfluoroheptanesulfonic acid (PFHpS), perfluoroheptanoic acid (PFHpA), perfluorohexanesulfonic acid (PFHxS), perfluorohexanoic acid (PFHxA), perfluorononanoic acid (PFNA), perfluorooctanesulfonic acid (PFOS), perfluorooctanoic acid (PFOA), perfluoropentanesulfonic acid (PFPeS), perfluoropentanoic acid (PFPeA), perfluoroundecanoic acid (PFUnA), N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA), N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA), perfluorotetradecanoic acid (PFTA), perfluorotridecanoic acid (PFTrDA), and Lithium

## ***IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?***

The results of Latham Water District's water quality testing show that we were in compliance with all applicable State and Federal drinking water quality requirements. However, we are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

## ***INFORMATION ON UNREGULATED CONTAMINANTS***

Between 2023 and 2025, Latham Water District is required to collect samples for 30 chemical contaminants under the fifth Unregulated Contaminant Monitoring Rule (UCMR 5). This action provides the Environmental Protection Agency (EPA) with scientifically valid data on the national occurrence of these contaminants in drinking water. Contaminants tested for include 29 per- and polyfluoroalkyl substances (PFAS) and lithium. The monitoring data on PFAS and lithium will help the EPA make determinations about future regulations. Latham Water District completed UCMR 5 testing in 2023 with no detected contaminants. You may obtain the complete set of UCMR 5 monitoring results by calling the Superintendent of the Division of Latham Water, Daniel Seaver, P.E., at (518) 783-2750.

## ***LEAD IN DRINKING WATER***

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Latham Water District is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. We encourage property owners to determine the material your water service is made of and report those results to the Latham Water District. Please scan the QR code on the right or go to the following website for additional information:

<https://survey123.arcgis.com/share/7ccf43ebf1fo46d58169eee5797907c4>



If you are concerned about lead in your water and wish to have your water tested, contact the Superintendent of the Division of Latham Water, Daniel Seaver, P.E. at 518-783-2750. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

***WHAT DOES THIS INFORMATION MEAN?***

As you can see by the table, our system had no violations of the State Sanitary Code. We have learned through our testing that some contaminants have been detected, however these contaminants were detected below New York State requirements.

***DO I NEED TO TAKE SPECIAL PRECAUTIONS?***

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease-causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice from their health care providers about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life.
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers.
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.
- You can play a role in conserving water by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. It is not hard to conserve water.



### **Conservation tips include:**

- Automatic dishwashers use 15 gallons of water for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water-using appliances. Then check the meter after 15 minutes, if the reading advanced, you have a leak.

## ***2023 CAPITAL IMPROVEMENTS***

- **RIVER ROAD STORAGE AND MOHAWK VIEW WATER TREATMENT PLANT MIXING UPGRADES**

Latham Water District started these upgrades in October of 2023. Two 24” transmission main valves were replaced and the 30” finished water high pressure interconnection improvements were completed at the end of the 2023.

- **BROOKHILL DRIVE, CASCADE TERRACE AND ASHFORD LANE WATER MAIN REPLACEMENT PROJECT**

The Latham Water District awarded the construction contract to Anjo Construction of Colonie, NY to replace the 8-inch main along Brookhill Drive, Cascade Terrace and Ashford Lane (approximately 3,600 feet). The contractor’s bid price for this project was \$1,047,195. The existing 8-inch cast iron main was installed in 1973 and has shown a significant increase in water main breaks. Latham Water District replaced the water main with polywrapped ductile iron pipe to improve reliability and the available fire flow to these areas of the water distribution system. Construction commenced late summer of 2023 and was substantially completed by December of 2023. The contractor will return in the Spring of 2024 to finalize restoration.

## ***2024-2025 PLANNED CAPITAL IMPROVEMENTS***

- **RIVER ROAD STORAGE AND MOHAWK VIEW WATER TREATMENT PLANT MIXING UPGRADES (continued)**

The Latham Water District awarded contract for the River Road Storage and Mixing Upgrades to DN Tanks. The remainder of the project will include the following improvements: demolish existing River Road clearwells; construct a new 2.0 million gallon clearwell with its associated piping, valves and mixer; rehabilitate existing control valves; concrete repair and the installation of an epoxy liner in the settled water flume; modify inlet piping at the backwash pump station to improve chemical mixing; replace Mohawk View Water Treatment Plant filter valves/actuators and modify piping to incorporate automatic filter to waste capabilities on filters 1-6.

- **WATER STORAGE TANK REHABILITATION**

The Latham Water District will issue a Request For Proposal (RFP) for engineering services to prepare plans and specifications for a complete rehabilitation of the 3.4 Million Gallon (MG) Tamarack Water Storage Tank, 2.3 MG John Street Water Storage Tank and the 0.75 MG Mohawk View Backwash Tank. The selected engineer will prepare an Engineer’s

Report in accordance with Section 202B of Town Law. This report will include a preliminary estimate of cost and an estimated impact to the rate payers of the Latham Water District. Once this Engineer's Report is complete, the Latham Water District will evaluate the available capital improvement funds and direct the selected engineer to prepare a bid package.

### ***ONLY TAP WATER DELIVERS***

How often do you think about your tap water? If you're like most, probably not often. Tap water delivers so many things that no other water can deliver.



- ◆ It delivers public health.
- ◆ It delivers fire protection.
- ◆ It delivers economic development.
- ◆ It delivers quality of life.

For more information go to [www.awwa.org](http://www.awwa.org) and/or [www.drinktap.org](http://www.drinktap.org)

### ***CLOSING***

Latham Water District delivered safe water in 2023 with no water quality violations. We continually strive to improve our water quality by improving our treatment processes and implementing capital improvement projects. In spite of everyday challenges in the water business, the Latham Water District and its employees continue to deliver safe drinking water to the residents and businesses we serve. This water supply statement is being prepared for our customers in accordance with New York State Public Health Law. Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. This report is being made available by the Superintendent of the Division of Latham Water, Daniel Seaver, P.E. Any questions about this report (or the system in general) should be directed to him at 518-783-2750.

**SUPPLEMENT TO**  
**2023 Annual Drinking Water Quality Report**

**Latham Water District**  
**347 Old Niskayuna Road**  
**Latham, NY 12110**

**PWS Id No: NY0100198**

**Introduction**

This supplement to the 2023 Annual Water Quality Report (AWQR) for the Latham Water District has been prepared in accordance with New York State regulations. The purpose of this supplement is to provide analytical results for samples of sources of water supply that are not required as part of the traditional AWQR process.

Current drinking water regulations require sampling and reporting on certain perfluoroalkyl substances, commonly referred to as PFAS. The three contaminants that were regulated in 2023 were PFOA, PFOS, and 1,4-Dioxane. The compliance data for these three compounds can be found in the published 2023 AWQR. However, in 2022 and 2023, Latham Water District decided to do additional sampling for unregulated perfluoroalkyl substances at each of the wells that provide raw water to the Mohawk View WTP. The results do NOT reflect the actual quality of your drinking water, but the raw water quality prior to treatment and delivery to your home.

**What does this information mean?**

As seen in the table below, all three raw water wells tested had concentrations below the MCL. We will continue to monitor these wells for PFAS compounds and will adjust operations as needed to comply with all applicable drinking water standards.

Supplemental Table Raw Water Unregulated Perfluoroalkyl Substances											
Contaminant	Violation Yes/No	Date or Frequency of Sample	Level Detected Average or Max (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, MRDL, TT, or AL)	Likely Source of Contamination				
<b>Synthetic Organic Contaminants</b>											
<b>Raw Water Well #3</b>											
PFBA	No	10/3/2022	2.6	ng/L	n/a	MCL=10 <sup>-1</sup>	Released into environment from widespread use in commercial and industrial applications				
PFPeA	No	10/3/2022	2.2								
PFOS	No	10/3/2022	8.6								
<b>Raw Water Well #4</b>											
PFBA	No	10/3/2022	2.0								
PFOS	No	10/3/2022	2.1								
<b>Raw Water Well #5</b>											
PFBA	No	10/3/2022	2.9								

PWS Id No: NY0100198

Analysis performed or reviewed by NY ELAP Lab Id No: 10000

**Notes:**

<sup>1</sup> These levels were found in raw water. PFOA and PFOS have a regulatory limit of 10 ng/L each in finished water. All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL=0.05 mg/L. US EPA Healthy Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be construed as legally enforceable federal standards and are subject to change as new information becomes available.

**Definitions:**

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as possible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Nanograms per liter (ng/L):** Corresponds to one part of liquid in one trillion parts of liquid (parts per trillion – ppt).

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.