

E. TOWN OF COLONIE PURE WATER DEPARTMENT

The following comments are taken from a letter dated April 26, 1996 from Dave McMorris of the Town of Colonie Pure Waters Department. A copy of the letter is provided in Appendix 1.

1. Comment:

Figure No. II-G-6 depicts 6" sewer for sewer mains which are 8". This sizing error should also be changed under the Sanitary Sewer section on page II-52. Also our 12" sewer in the vicinity of Morris Road should be shown to connect to the 20" sewer trunk line.

Response:

The correction is noted and is illustrated on revised Figure II-G-6.

2. Comment:

The report does not indicate the existence of an Intermunicipal Agreement with the Town of Niskayuna for sewer service. The report should also indicate that the Town of Colonie where feasible, would explore the possibility of entering int Intermunicipal Agreements with neighboring communities for sewer service. This information should be incorporated in the first paragraph on page II-53.

Response:

It is recognized that the Town of Colonie has an intermunicipal agreement with the Town of Niskayuna for sewer service. It also recommended that the Town of Colonie develop additional agreements with neighboring municipalities, where practical. The intermunicipal agreements which could be developed for both water and sewer service, could help defray costs associated with the design and construction of new utilities, and provide for better regional planning of water supply and sewage disposal.

3. Comment:

On page II-53, in the paragraph that begins with "As part of the West End...", the wording should be changed to "As part of the West End Sewer Project Study. the Town, in the future, plans on installing a sewer collection system and pump station to provide sewer service to the northwest portion of the study area

**MOHAWK VIEW
WATER POLLUTION
CONTROL FACILITY**

**LISHA KILL
PUMP STATION**

**PROJECT
STUDY AREA**

KEY

	8"
	10"
	12"
	16"
	18"
	20"
	24"
	30"
	42"
	48"

EXISTING SANITARY SEWER COLLECTION SYSTEM

LISHA KILL - KINGS ROAD AREA

GENERIC ENVIRONMENTAL IMPACT STATEMENT



CHA
CLOUGH, HARBOUR & ASSOCIATES LLP
ENGINEERS, SURVEYORS, PLANNERS & LANDSCAPE ARCHITECTS
III. WINNERS CIRCLE - ALBANY, NEW YORK - 12205

FIGURE NO. II-G-6 (REVISED) SCALE: 1" = 3500'

11/23/11 01:15:34M DWG 11-3500-EG-6 3/1/16

including Michael Dr., St. Marie St., St. Ann St., St. Joseph St. and a portion of Kings Rd.

Response:

The correction is noted.

4. Comment:

The first paragraph on page II-57 under Sanitary Sewer, refers to projected average daily flows and peak flows. The information shown does not reflect projected flow numbers that were originally indicated to our Department. It also indicates a peaking factor of 4.0 is used in accordance with this Department. Prior correspondence with Clough Harbour indicated a peaking factor of 2.9 was going to be used as per the Ten State Standards.

Response:

By the end of the planning period, the projected peak hourly wastewater flow for the study area, using a peaking factor of 2.9 as per Ten State Standards, is 1.8 GPH.